



- Legend:-**
- 1950x500x2000mm Cabinet
  - 1600x500x2000mm Cabinet
  - Ⓢ Smoke Detector with Sounder
  - Ⓢ Smoke Detector
  - FAP Fire Alarm Panel
  - ⊙ 2 KG Co2 Extinguisher
  - ⊙ 2 KG Co2 Extinguisher
  - 6 ltr SP Ecofoam Extinguisher
- Above extinguishers to be mounted on double stand with back board, Fire Action Notice Board, Fire Exit Up Sign and Extinguisher ID

1600mm Cabinet		1950mm Cabinet	
Shelf Number	Total Capacity	Shelf Number	Total Capacity
1	3.2m <sup>2</sup>	1	3.9m <sup>2</sup>
2	3.2m <sup>2</sup>	2	3.9m <sup>2</sup>
3	3.2m <sup>2</sup>	3	3.9m <sup>2</sup>
4	3.2m <sup>2</sup>	4	3.9m <sup>2</sup>
5	3.2m <sup>2</sup>	5	3.9m <sup>2</sup>
6	3.2m <sup>2</sup>	6	3.9m <sup>2</sup>
7	3.2m <sup>2</sup>	7	3.9m <sup>2</sup>
8	3.2m <sup>2</sup>	8	3.9m <sup>2</sup>
9	3.2m <sup>2</sup>	9	3.9m <sup>2</sup>
10	3.2m <sup>2</sup>	10	3.9m <sup>2</sup>
11	3.2m <sup>2</sup>	11	3.9m <sup>2</sup>
<b>Total</b>	<b>35.2m<sup>2</sup></b>	12	3.9m <sup>2</sup>
		13	3.9m <sup>2</sup>
		14	3.9m <sup>2</sup>
		15	3.9m <sup>2</sup>
		16	3.9m <sup>2</sup>
		17	3.9m <sup>2</sup>
		18	3.9m <sup>2</sup>
		19	3.9m <sup>2</sup>
		<b>Total</b>	<b>74.10m<sup>2</sup></b>
		<b>Total Cabinet Capacity</b>	
		1600mm Cabinet	35.2m <sup>2</sup>
		1950mm Cabinet	74.1m <sup>2</sup>
		<b>Total</b>	<b>109.3m<sup>2</sup></b>

**2.9.11 Fixed obstructions/furnishings**  
 Storage areas of buildings with fixed obstructions should provide unobstructed access to an exit. Access to an exit in such buildings may be by way of a gangway. The width of gangways between fixed obstructions (including fixed racking or shelving and high-bay storage) should be at least 530mm. Due to the low occupancy and limited occupation in a building for the bulk storage of spirituous liquors, the width may be reduced to at least 400mm.

Rev.	Description	Date	Initials	Checked
A	Internal shelving layout overlaid	June 24	BM	

Status: APPROVAL

Client: Chivas Brothers  
Pernod Ricard

Location: KILMALID STRILING ROAD DUMFRIE

Drawing Title: DEVELOPMENT OF AREA TO SOUTH OF KILMALID BOTTLING COMPLEX NEW STAFF SHOP LAYOUT

Date: JUN 24  
 Drawn by: AM  
 Scale: 1:25  
 Checked: ?  
 Date: JUN 24

Project Ref: 9077  
 Dwg. No: C090  
 Rev: A

CHARLES SCOTT & PARTNERS CONSULTING ENGINEERS  
 Ventlaw Building  
 349 Bath Street  
 Glasgow G2 4AA  
 Tel: 0141-331-2454  
 Fax: 0141-332-2873  
 www.csandp.co.uk